

22.09.2025
Benjanapadavu

From
System Admin
CEC, Benjanapadavu
Through,
Dean facilities
CEC, Benjanapadavu.
To
The Secretary
CHSA, Mangalore.

Dear Sir,

Sub: Approval for Repair of 2 aplab UPS

With reference to the above, our two ups are having problem and need urgent service. For above we have got the quotation from aplab. I am attaching the quote with this letter please approve the same.

Regards


Suresh Nayak H
System admin

1
18998 - Audi UPS
14160 → UPS Room!

33158

34k approx.
Forwarded for
Approval
Anil

Quotation

REF: SW/MNG/25038

Date:19/9/2025

To,

The Principal

Canara Engineering College

Benjanapadavu

Mangalore

Subject: **Quotation for the Repair of UPS**

Sir,

With reference to above we thanks for the kind courtesy extended to our engineer who visited to attend the breakdown call for the 20KVA UPS installed at your institution. During the Preliminary inspection following spares are found faulty and need to be repair/Replace with the new cards/Components .the service/Spares charges are estimated are as follows

SL. No	Description	Service Charges in RS
01	Service /Spare charges for the Repair of 20KVA UPS Model:LP1020 Sr.no:HO11UPS041269 Charger Card No 507 and CH24 Input Reference Transformer IGBT Module(200GB) 2 no's Driver Card No 509C 1 set Inverter Card 262C 1set	3,500.00 2,600.00 4,000.00 2,500.00 3,500.00
	Add:GST@18%	2,898.00
	Total	18,998.00

Kindly approve the Quotation to take up the job

Thanking you & assuring you our prompt attention at all time.

For APLAB Limited



Girish

Audi UPS

W.O may be k&sm

23/9/25