



CANARA ENGINEERING COLLEGE

SUDHINDRA NAGARA, BENJANAPADAVU, BANTWAL TQ, D.K - 574219



Date: 07/1/2026

From,

Prajwal Tellis
Resident Engineer
Canara Engineering College,
Benjanapadav.

wo/ce

To,

Principal
Canara Engineering College
Benjanapadav

Through,

Dean
Administration
Canara Engineering College
Benjanapadav

Respected Sir,

Sub: Request for Approval to Replace Choked Air Filter of college DG-125 KVA

During inspection, it was observed that the air filter OF college dg 125KVA is choked, and replacement is recommended to ensure proper and efficient operation of the equipment. In this regard, we kindly request your permission to replace the air filter. The total cost for the replacement is **Rs. 6,101.**

Thanking you,

Yours Sincerely

Prajwal Tellis
7/1/26

forwarded for approval
Ante...

approved
8.1.26

Enclosure: -1) Quotation

a) service report



College Da-125KVA

Customer Quotation

MANIRANJAN DIESEL SALES & SERVICE PRIVATE LIMITED (Authorized Dealer For Cummins India Limited) B 105 / 106, INDUSTRIAL ESTATE, MANGALORE, 575011 Phone: 0824-2407442 Fax: Email: partsmangalore@maniranjan.com CIN: GSTIN: 29AABCM9631K1Z1 PAN No: AABCM9631K Statutory Tax Info:	Quotation Number:	QT-MS-MG-2526-06131	Opportunity No:	OPP-MS-MG-2526-06131	Payment QR 
	Quote Date:	07-01-2026	Revision #:	1	
	Number of Items:	3	Valid Up To:	06-02-2026	
	Service Representative		Sales Representative		
	Engine Serial #		Account Alias		
	Engine Model				

Shipping Instructions	
Indentor:	Consignee:
CANARA HIGH SCHOOL ASSOCIATION CANARA ENGINEERING SITE : CANARA ENGINEERING COLLEGE BENJANAPADAVU, BANTWAL TALUK Other, BANTWALA, 574219 Karnataka GSTIN: 29AAAAC0920C1ZF Contact Name: Mobile: Email Id:	CANARA HIGH SCHOOL ASSOCIATION CANARA ENGINEERING SITE : CANARA ENGINEERING COLLEGE BENJANAPADAVU, BANTWAL TALUK Other, BANTWALA, 574219 Karnataka GSTIN: 29AAAAC0920C1ZF Contact Name: Mobile: Email Id:
Indentor Site: Karnataka	Consignee Site: Karnataka
Remarks: ESN-62682031MODEL-6BtA5.9 125KVA	

Item Details:

Sr.No	Item Name	Customer ItemRefNo	Item Description	HSN/SAC	Qty	UoM	Unit Price (Rs.)	Total Amt	Net Taxable Amt	CGST Tax Amt	SGST Tax Amt	Amount
1	MRDSS- SF- TRANSPORT - 18%		TRANSPORTATION CHARGES	998719	750.00	Each	1.00	750.00	750.00	67.50 (9.00%)	67.50 (9.00%)	885.00
2	3814696		ELEMENT, AIR CLEANER	84213100	1.00	Each	738.1355932	738.14	738.14	66.43 (9.00%)	66.43 (9.00%)	871.00
3	3814695		ELEMENT, AIR CLEANER	84213100	1.00	Each	3682.20339	3682.20	3682.20	331.40 (9.00%)	331.40 (9.00%)	4345.00
Total:							4421.3389832	5170.34	5170.34	465.33	465.33	6,101.00

Terms and Condition

1. Introduction

These Terms and Conditions ("Terms") govern the provision of quotations and any subsequent agreements between Maniranjan Diesel Sales & Service Pvt Ltd ("the Company," "we," "us," or "our") and the customer ("you" or "the Customer") relating to the supply of goods and/or services ("Products"). By requesting a quotation or accepting a quotation from the Company, you agree to be bound by these Terms.

2. Quotation Validity

2.1. All quotations issued by the Company are valid for 30 days from the date of issue, unless otherwise stated in writing. After this period, the quotation is subject to review, and any prices or terms may change.

2.2. Quotations are based on current market conditions and may be subject to adjustments if costs increase due to factors such as changes in supply prices, exchange rates, taxes, tariffs, or unforeseen circumstances beyond the Company's control.

3. Accuracy of Information

3.1. The Company makes reasonable efforts to ensure that all details, including descriptions, specifications, and pricing provided in a quotation are accurate and complete at the time of issue.

3.2. If any discrepancy is found, the Company will notify the Customer and provide updated information.

4. Acceptance of Quotation

Taxes	Amount
Total Base Amt	5,170.34
Total Discount Amt	0.00
Total Taxable Amt	5,170.34
IGST Tax Amt	0.00
CGST Tax Amount	465.3306
SGST Tax Amount	465.3306
Tcs Amt	0.00
Total Tax Amt	930.66
Round Off	0.00
Total Amt	6,101.00

Handwritten signature and date:
 8/1/26

College DG-125KVA



**Distribution Business Unit
Cummins Field Service Report
MANIRANJAN DIESEL SALES & SERVICE
PRIVATE LIMITED**

Dealership Branch : Maniranjan -
Mangalore
Single Point Contact No.:0824-2407442
Customer care email ID



Service Order Type : AMC Service	Sub Type : PM	Service Order Number : SON-MS-MG-2526-02979	FSR No : FSR-SA-6428863	Date :26-12-2025
Customer Name : CANARA ENGINEERING COLLEGE	Contact Person Name : PRAJWAL TELLIS	Designation : ELECTRICAL ENGINEER	Contact No : 9483622205	
Customer Address : CANARA ENGINEERING COLLEGE BENJANAPADAVU,BANTWAL TALUK - 574219 KARNATAKA		Customer Primary Email Id : prajwal.mvsit@gmail.com	Customer Secondary Email Id :	
ESN : 62682031	Gen/Equip Model : UC2744V1	Alternator Sr. No :	Equip Sr. No : NA	Current Hours : 4217.00 Cumulative Hours : 4217.00 Component Hours :
Engine Model : 6B	OEM : POWERICA	Avg. Monthly Running Hrs :	Last B Check done at Hrs & Date :4212,25-11-2025 Last C Check done at Hrs & Date : , Last D Check done at Hrs & Date : 4212, Air Cleaner element replaced Hrs & Date:., Battery replaced at Hrs & Date:., Coolant replaced at Hrs & Date:.,	
kVA Rating : 125	Branch Code : NA	Employee Number : NA		
Digital Failure Code :	Brand and Grade of Lube Oil used : VALVOLINE	Type of Coolant Used : Fleetguard premixed 50 50 Battery Make : EXIDE Model : 12V 150Ah Battery Sr No. : 12V 150Ah		
Controller Type : PSO600		Coolant Concentration Level : 9.00		

Engine Performance Parameters				Service Request Details	
Low Idle RPM	0	Low Idle Pressure	0.00 0.00	Response to Service Request	Date/Time
High idle RPM	1520	High Idle pressure	490.00 490.00	PM/Failure Date	23-12-2025 12:56:00 PM
Full Load RPM	0 RPM	Full Load pressure	0.00 0.00	Failure Reported on	23-12-2025 12:56:46 PM
Coolant Temp (Degree/C)	65.00	Lube Oil Temp (Degree/C)		Customer Requested on	24-12-2025 9:00:00 AM
Cranking Voltage	9.00 Volts			Attended on	24-12-2025 9:31:28 AM
Parameters for Generator Set		Parameters for Other applications		Diagnosis Completed on	
Voltage(AC)	415	Frequency (HZ)	50.00	Drilling Speed (Rpm)	Required Material Received on
Current (Ac/Ampere)	0 0	Load(KW)		Gear Speed (Rpm)	Actual Resolution Date
Stray Voltage(DC volts)	0.00	Ripple Voltage (AC volts)	0.00	Power Factor	26-12-2025 11:21:41 AM

Customer Complaint : GENERAL INSPECTION

Inspection/Observation and Work Done in Brief : Visited the site, checked the oil level, coolant level and found normal. Removed air filter and found choked, fitted back. Checked the tightness of clamps of hoses, alternator sensing cables, battery terminal connections and found normal. Run the DG and DG running condition found ok.

Problem Resolution/Solution : Carried out general inspection and tested

Recommendation/Suggestion :NA

Customer Observation Date :

Problem Status : Closed
Customer's Remarks:GOOD

Responsibility (If Status is Open) :
Customer Experience :Satisfied

Service Representative's Name : ROYSTON LOBO
Customer Representative's Name: GANESH

Cummin's ID No: 1223514HAC
Service Rep Signature and Date : 26-12-2025 11:21:33 AM
Customer Signature and Date : 26-12-2025 11:21:03 AM

Promotion ID No: 1223514

NO IMAGE AVAILABLE

[Handwritten Signature]